

کنترل پروژه تعمیرات اساسی واحد ۳



ID	Task Name
۱	پمپ های آب کندانسیت-MTA
۲	START
۳	A- CP SUCTION STRAINER
۴	START (WORK REQUEST & ISOLATION)
۵	STRAINER DISASSEMBLING & SCREEN REMOVAL
۶	V.I FOR ANY CORROSION OR ERROSION
۷	SCREEN CLEANING OR REPLACEMENT
۸	SCREEN INSERTION & STRAINER ASSEMBLING
۹	END (WORK FINISH CONFIRM)
۱۰	A_ CP
۱۱	START (WORK REQUEST & ISOLATION)
۱۲	PUT RELATED STARTER IN TEST POSITION & INSTALL DANGER CARD
۱۳	DISCOUPLE PUMP & MOTOR
۱۴	DISASSEMBLE PUMP & REMOVE BARREL FOR SANDBLUST & WELLDING & LINNING
۱۵	ALL PARTS CLEANING & ROUTIN SERVICES
۱۶	CASING INSPECTION & REPAIR OR REPLACE
۱۷	BEARINGS V.I OR REPLACE
۱۸	IMPELLERS V.I & REPAIR OR REPLACE
۱۹	BUSHES & WEAR RINGS V.I & REPLACE
۲۰	INSPECT SEAL MECHANISM PARTS & REPAIR OR REPLACE
۲۱	REPLACE O-RINGS & GASKETS
۲۲	CARRY OUT REQUIRED CLEARANCE CHECKS
۲۳	BARREL INSTALLATION
۲۴	ASSEMBLE PUMP
۲۵	CONNECT & ALIGN PUMP WITH MOTOR
۲۶	COORDINATION WITH COMMISSIONING GROUP FOR PUMP LOAD TEST
۲۷	MECHANICAL & ELECTRICAL TESTS BEFORE START UP (ACCORD. TO CHECK LIST)
۲۸	PROCESS LINE_UP (REMOVE ISOLATION)
۲۹	PUT RELATED STARTER IN SERVICE & REMOVE DANGER CARD
۳۰	PUMP LOAD TEST (MECHANICAL SUPERVISION)
۳۱	PUMP LOAD TEST (ELECTRICAL SUPERVISION)
۳۲	BALANCE PUMP WITH MOTOR IF NECESSERY
۳۳	B- CP SUCTION STRAINER
۴۰	B_ CP
۶۳	FINISH